CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 23/07/2019

: **CP-2019-09-12-35**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 18-07-19

: Sump Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 23/07/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	16/07/2019	23/07/2019	151.30 X 151.08 X 150.79	22858	**8.569**	534.0	23.4	23.0
M25	16/07/2019	23/07/2019	149.94 X 150.07 X 150.03	22502	**8.902**	509.0	22.6	
M25	16/07/2019	23/07/2019	150.06 X 150.93 X 150.25	22649	**8.452**	518.9	22.9	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 18-07-19

: Sump Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
M25	16/07/2019	13/08/2019	150.47 X 149.65 X 150.96	22518	**8.692**	626.7	27.8	27.7
M25	16/07/2019	13/08/2019	150.25 X 150.01 X 151.56	22540	**8.542**	595.4	26.4	
M25	16/07/2019	13/08/2019	150.57 X 149.10 X 149.53	22449	**8.525**	650.7	29.0	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

2924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	13/08/2019	150.21 X 150.37 X 150.58	22587	**8.569**	533.4	23.6	22.9
Roof Concrete	M25	05/08/2019	13/08/2019	150.61 X 151.07 X 150.25	22752	**8.902**	512.9	22.5	
Roof Concrete	M25	05/08/2019	13/08/2019	150.69 X 150.39 X 150.69	22662	**8.452**	509.9	22.5	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

2924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 18-07-19

: Sump Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Sump Concrete	M25	16/07/2019	13/08/2019	150.17 X 150.96 X 149.52	22669	**8.692**	632.6	27.9	27.5
Sump Concrete	M25	16/07/2019	13/08/2019	149.41 X 149.79 X 151.97	22380	**8.542**	589.9	26.4	
Sump Concrete	M25	16/07/2019	13/08/2019	149.68 X 150.11 X 151.23	22468	**8.525**	637.0	28.4	

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	13/08/2019	150.19 X 150.38 X 150.56	22586	**8.569**	532.1	23.6	22.7
Roof Concrete	M25	05/08/2019	13/08/2019	149.22 X 150.00 X 150.77	22383	**8.902**	501.5	22.4	
Roof Concrete	M25	05/08/2019	13/08/2019	150.45 X 149.09 X 149.87	22430	**8.452**	496.1	22.1	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 03/09/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	03/09/2019	149.78 X 151.89 X 150.60	22750	**8.692**	617.7	27.2	27.4
Roof Concrete	M25	05/08/2019	03/09/2019	150.46 X 150.44 X 150.95	22635	**8.542**	601.6	26.6	
Roof Concrete	M25	05/08/2019	03/09/2019	151.84 X 151.54 X 149.63	23009	**8.525**	654.6	28.4	

CIVIL Pro Sig. Date. BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	13/08/2019	149.11 X 152.00 X 151.86	22665	**8.569**	537.9	23.7	22.8
Roof Concrete	M25	05/08/2019	13/08/2019	149.55 X 151.94 X 150.80	22723	**8.902**	509.8	22.4	
Roof Concrete	M25	05/08/2019	13/08/2019	149.14 X 150.69 X 150.12	22474	**8.452**	498.4	22.2	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro ★ Sig..... Date..... ★ BANGALORE

****End of Report****

2924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 03/09/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	03/09/2019	150.17 X 151.87 X 149.51	22807	**8.692**	638.4	28.0	27.8
Roof Concrete	M25	05/08/2019	03/09/2019	151.19 X 150.11 X 150.91	22694	**8.542**	611.7	27.0	
Roof Concrete	M25	05/08/2019	03/09/2019	151.02 X 151.60 X 150.01	22896	**8.525**	653.8	28.6	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 03/09/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 28 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	03/09/2019	151.87 X 150.15 X 149.53	22804	**8.692**	626.2	27.5	27.7
Roof Concrete	M25	05/08/2019	03/09/2019	149.65 X 149.54 X 151.41	22380	**8.542**	600.3	26.8	
Roof Concrete	M25	05/08/2019	03/09/2019	150.80 X 151.30 X 151.91	22815	**8.525**	655.4	28.7	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 08-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	06/08/2019	13/08/2019	150.37 X 151.95 X 149.93	22849	**8.569**	528.6	23.1	
Roof Concrete	M25	06/08/2019	13/08/2019	149.98 X 150.82 X 151.02	22621	**8.902**	506.1	22.4	22.7
Roof Concrete	M25	06/08/2019	13/08/2019	149.75 X 150.78 X 151.63	22579	**8.452**	506.8	22.4	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 03/09/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

: 07-08-19

: GF Roof Concrete

Size : 150X150X150 mm

Age : M25 / 28 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	05/08/2019	03/09/2019	151.14 X 150.76 X 149.43	22786	**8.692**	617.2	27.1	27.5
Roof Concrete	M25	05/08/2019	03/09/2019	150.72 X 149.66 X 150.29	22557	**8.542**	597.3	26.5	
Roof Concrete	M25	05/08/2019	03/09/2019	149.16 X 149.89 X 150.12	22357	**8.525**	646.1	28.9	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 13/08/2019

: **CP-2019-09-12-35**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

: EE(Project)/Ynk Zone/WO/114/2017-18

: 08-08-19

: GF Roof Concrete

: 150X150X150 mm

: M25 / 7 Days Compressive Strength

: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm²)	Average Compressive Strength (N/mm²)
Slab/Concrete	M25	06/08/2019	13/08/2019	151.10 X 151.19 X 149.35	22845	**8.569**	540.7	23.7	23.1
Slab/Concrete	M25	06/08/2019	13/08/2019	150.04 X 151.26 X 150.34	22695	**8.902**	521.6	23.0	
Slab/Concrete	M25	06/08/2019	13/08/2019	150.30 X 149.71 X 151.21	22501	**8.452**	506.2	22.5	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 03/09/2019

: **CP-2019-09-12-35**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

ipt : 08-08-19

ID : GF Roof Concrete

/Size : 150X150X150 mm

de/Age : M25 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	06/08/2019	03/09/2019	151.67 X 149.80 X 149.29	22719	**8.692**	622.4	27.4	27.6
Roof Concrete	M25	06/08/2019	03/09/2019	149.93 X 149.48 X 151.33	22411	**8.542**	602.1	26.9	
Roof Concrete	M25	06/08/2019	03/09/2019	149.07 X 150.17 X 151.40	22385	**8.525**	641.7	28.7	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 13/08/2019

: CP-2019-09-12-35

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

ipt : 08-08-19

D : GF Roof Concrete

pe /Size : 150X150X150 mm

ade/Age : M25 / 7 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	06/08/2019	13/08/2019	151.94 X 151.73 X 151.10	23055	**8.569**	545.7	23.7	23.1
Roof Concrete	M25	06/08/2019	13/08/2019	149.43 X 150.12 X 151.40	22433	**8.902**	515.3	23.0	
Roof Concrete	M25	06/08/2019	13/08/2019	151.90 X 149.28 X 150.11	22676	**8.452**	514.2	22.7	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35

Date: 03/09/2019

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

ipt : 08-08-19

ID : GF Roof Concrete

Type /Size : 150X150X150 mm

ade/Age : M25 / 28 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	06/08/2019	03/09/2019	150.62 X 151.75 X 149.14	22857	**8.692**	624.7	27.3	27.4
Roof Concrete	M25	06/08/2019	03/09/2019	150.22 X 150.91 X 150.77	22670	**8.542**	607.7	26.8	
Roof Concrete	M25	06/08/2019	03/09/2019	149.22 X 151.86 X 151.36	22661	**8.525**	635.7	28.1	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |